

# City of Trenton 2014 Water Quality Data

## KY1100428

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Unless otherwise noted, the report level is the highest level detected.

	Allowable Levels	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source
Turbidity (NTU) TT * Representative samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples	0.091	100	No	Soil runoff

### Regulated Contaminant Test Results

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Barium [1010] (ppm)	2	2	0.025	0.025 to 0.025	Jun-14	No	Drilling wastes; metal refineries; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	0.94	0.94 to 0.94	Jun-14	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	0.26	0.26 to 0.26	Feb-14	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits

### Disinfectants/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.69 (lowest average)	1.45 to 1.94 (monthly ratios)	2014	No	Naturally present in environment.
---	-----	-----	-----------------------	-------------------------------	------	----	-----------------------------------

\*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.47 (highest average)	0.2 to 2.03	2014	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	44 (high site average)	33 to 56 (range of individual sites)	2014	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	56 (high site average)	37 to 81 (range of individual sites)	2014	No	Byproduct of drinking water disinfection.